

AEROBARRIER™

Breakthrough Envelope Sealing Technology

Certificate of Completion

Envelope Sealing Performed For:

Building America Project
Lakeville, MN 55044

Overall Sealing Results

When we arrived,
YOUR HOME HAD:

2507.9 CFM of Leakage, equivalent to a
312.6 Square Inch Hole or **5.4 Air Changes**
per Hour


*(for your 3500 square-foot structure enclosing an
approximate volume of 28000 cubic feet).*

After we finished,
YOUR HOME HAS:

297.8 CFM of Leakage, equivalent to a
37.1 Square Inch Hole or **0.6 Air Changes**
per Hour

This corresponds to a **88.1% Reduction in**
Envelope Leakage.

Note: Envelope leakage and air-change results are
calculated at a standard pressure of 50 Pa.



Aeroseal Technician

Aeroseal Case ID **9928**

Date of Seal **5/30/2017**

System Description **Home Envelope**

Seal Description **Envelope Sealing**

Hardware **EnvelopeSeal**

Envelope Sealing Performed By:

Aeroseal LLC
7989 S Suburban Rd
Centerville, OH 45458
Phone: 937.428.9300